



Government of West Bengal
Office of the Block Development office
Barasat, North 24 parganas

APPENDIX-III

PRO FORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


Memo No: **2483** BST1

Date: 23.11.2023

It is certified that an inspection team headed by MD Sahauddin Molla, FS(MNB) district water sanitation cell from Barasat-I Block Development Office, inspected the Delhi world public school Barasat, vill-Madhupur, (kadambagachi), PO- Badu, PS-Duttapukur, North 24 Parganas Pin 700128 on 23.11.2023 time 11 a.m.

It has been found that the Delhi World Public School Barasat has safe drinking water facilities for the students Teaching and non Teaching staff of the institution and maintaining the hygienic sanitation condition in the school building & campus as the norms prescribed . As per Water Testing Report by Barasat Sub-Division, PHED North 24 Parganas.

The above is valid for a period up to 28 September, 2024


Signature with Seal: 
Name: **RATIB DUTTA CHOWDHURY**
Designation: **Block Development Officer**
Barasat-I Dev. Block, 24 Pgs. (N)

Name & Address of the office / Development

To
Delhi World Public School Barasat
Vill-Madhupur, (Kadambagachi) PO-Badu,
PS- Duttapukur, North 24 Parganas, West Bengal, PIN-700128
(Name & Address of the Institution)

DELHI WORLD PUBLIC SCHOOL BARASAT


Principal

Delhi World Public School, Barasat

Manager

**PUBLIC HEALTH ENGINEERING DTE.
BISHNUPUR SUB DISTRICT WATER TESTING LABORATORY**

Agency Name **DELHI WORLD PUBLIC SCHOOL BARASAT**

GRN No: **192023240256610R18**

Work Order No.:

Date

Water sample collected by **Party** **DELHI WORLD PUBLIC SCHOOL BARASAT** Date of collection **16.10.2023**

GRN Date: **12.10.2023**

SL. NO.	Municipality/Block Name	G.P. Name / Mouza Name	Habitation & Landmark	Type of Source	Depth of tubewell in mtr	CHEMICAL TEST RESULTS						BACTERIOLOGICAL TEST RESULTS			Remarks				
						Date of Testing	pH	TDS mg/L	Turbidity (NTU)	Total Hardness as (CaCO ₃)	Cl mg/L	Mn mg/L	Total Fe mg/L	Total As mg/L		Date of Testing	Date of Completion	CFU of Total Coliforms at 370C per 100 mL	CFU of Faecal Coliforms at 370C per 100 mL
1	BARASAT		DELHI WORLD PUBLIC SCHOOL			16.10.2023	6.49	240.6	0.00	30.48	28.28	0.00	0.148	0	16.10.2023	17.10.2023	0	0	

Signature of Asstt. Engineer
Sub District Chemist Laboratory
Bishnupur Sub District Water Testing Laboratory
Barasat Sub Division, PHED

Signature of Asstt. Engineer
R.W.S. Barasat Sub Division, PHED

Signature of Executive Engineer
Barasat Division, PHED

Drinking water specification : IS: 10500, 2012

Sl. No.	Parameter	Acceptable limit	Permissible limit in absence of alternate source
1	pH	6.5 - 8.5	No relaxation
2	TDS	500 mg/L	2000 mg/L
3	Mn	0.10 mg/L	0.30 mg/L
4	Turbidity (NTU) Max	1	5
5	Total Hardness (as CaCO ₃)	200 mg/L	600 mg/L
6	Cl	250 mg/L	1000 mg/L
7	Fe	0.30 mg/L	1.0 mg/L
8	As	0.01 mg/L	No relaxation

Water sample is collected by the party. Laboratory is not liable for source of the water sample.

BDL -- Below Detection Limit.

Bacteriological Drinking Water Specification, BIS: 10500, 2012	
Note: Minimum limits as per Cl. 3.2.1. of IS-10500	
a)	Throughout any year, 95% of samples should not contain any coliform organisms in 100 ml.
b)	No sample should contain coliforms organisms per 100 ml
c)	Coliform organisms should not be detectable in 100 ml of any two consecutive samples.

DELHI WORLD PUBLIC SCHOOL BARASAT

Signature
Principal

Delhi World Public School, Barasat

Signature
Manager